



SAV Series 2472 Wet Barrel Hydrants

AWWA C503 and UL Certificate of Compliance

This letter is to certify that all Series 2472 ductile iron Wet Barrel Fire Hydrants manufactured by Steel Arch Valves Company in Kansas City, Kansas, meet or exceed the standards established by AWWA C503.

Each hydrant is tested, after assembly, to a static pressure of 700 psi and is rated to 350 psi. The UL working pressure rating is 250 psi.

In addition, all Steel Arch Valves fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of Steel Arch Valves,

A handwritten signature in blue ink, reading "John Wilber".

John Wilber

VP Engineering
Steel Arch Valves Company