



SAV Series 24 Wet Barrel Hydrants

AWWA C503 and UL Certificate of Compliance

This letter is to certify that all Series 24 bronze, stainless steel, and ductile iron Wet Barrel Fire Hydrants manufactured by Steel Arch Valves Company in Kansas City, Kansas, meet or exceed the standards established by AWWA C503.

Each hydrant is tested, after assembly, to a static pressure of 400 psi and is rated to 200 psi.

In addition, all Steel Arch Valves fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of Steel Arch Valves,

A handwritten signature in black ink, reading 'John Wilber', is placed above the printed name.

John Wilber

VP Engineering
Steel Arch Valves Company

Steel Arch Valves Company

14527 West 112th Street
Overland Park, KS 66210
An ISO 9001 and ISO 14001 registered company
© Copyright SAV Group.

Expect... The SAV logo is shown in blue, with the letters 'S', 'A', and 'V' in a stylized font.