



SAV Series 24 Ductile Iron Wet Barrel Hydrants

UL/FM Certificate of Compliance

This letter is to certify that the Series 24 ductile iron Wet Barrel Fire Hydrants manufactured by Steel Arch Valves Company in Kansas City, Kansas, meet or exceed the standards established UL 246 and FM1511. The hydrants are listed with UL and are FM approved.

Each hydrant is tested, after assembly, to a static pressure of 400 psi. The AWWA, UL and FM working pressure is rated to 200 psi.

In addition, all Steel Arch Valves fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of Steel Arch Valves,

A handwritten signature in blue ink, appearing to read 'John Wilber'.

John Wilber

VP Engineering
Steel Arch Valves Company

Steel Arch Valves Company

An ISO 9001 and ISO 14001 registered company
© Copyright SAV Group.

Expect... SAV