



SAV Series 25 and Series 45 Gate Valves

UL/FM Certificate of Compliance

This letter is to certify that all Series 25 Gate Valves; 2-½-inches through 12-inches and Series 45 Gate Valves; 2-½-inches through 16-inches manufactured by Steel Arch Valves Company in Kansas City, Kansas, meet or exceed the standards established UL and FM. The gate valves are listed with UL and ULC and are FM approved. 14- and 16-inch OS&Y valves are not included.

Each gate valve is tested, after assembly, to a static pressure of 500 psi. The UL and FM working pressure is rated to 200 psi for the Series 25 gate valves. The UL and FM working pressure is rated to 250 psi for the Series 45 gate valves through 12-inches and 200 psi for 14- and 16-inches.

In addition, all Steel Arch Valves gate valves have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of Steel Arch Valves,

A handwritten signature in blue ink, appearing to read 'John Wilber', is positioned above the printed name.

John Wilber

VP Engineering
Steel Arch Valves Company