



SAV Series 27 Dry Barrel Hydrants

AWWA/UL/FM Certificate of Compliance

This letter is to certify that the Series 27 Dry Barrel Fire Hydrants manufactured by Steel Arch Valves Company in Kansas City, Kansas, meet or exceed the standards established by the AWWA (C502 and C550), UL 246 and FM1510. The hydrants are listed with UL, ULC and are FM approved.

Each hydrant is tested, after assembly, to a static pressure of 500 psi. The AWWA, UL and FM working pressure is rated to 250 psi.

In addition, all Steel Arch Valves fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of Steel Arch Valves,

A handwritten signature in black ink, appearing to read 'John Wilber'.

John Wilber

VP Engineering
Steel Arch Valves Company

Steel Arch Valves Company

An ISO 9001 and ISO 14001 registered company
© Copyright SAV Group.

Expect... The SAV logo is shown in blue, with the letters 'S' and 'A' connected and the 'V' separate.